



NOTE:  
MANHOLES THAT CONTAIN AN INSIDE DROP OR SEWER DEEPER THAN 12 FEET  
WILL REQUIRE 5' DIAMETER MANHOLES.

<b>DORCHESTER COUNTY WATER &amp; SEWER</b>	
<b>STANDARD PRE-CAST MANHOLE</b>	DRAWING: <b>S-3</b>
DATE: <u>NOV. 2025</u>	DRAWN BY: <u>STL</u>
SCALE: <u>NTS</u>	APPROVED BY: <u>JDC</u>